
Plan Review Summary

Building Information

| | | | |
|--------------------|-----------------------------|-----------------|----------------------------|
| Project Name: | EBB Takayama Lab Renovation | Floor/Room #: | 4220-4230, 4236,4239, 4157 |
| Building #: | 195 | Department: | College of Engineering |
| Occupancy Type: | Business | Budget: | \$300,000 |
| Construction Type: | IIB | Type of Review: | Fire Alarm |

Project Management

| | |
|-------------------------------|------------------------|
| Project Manager: | Maria del Mar Ceballos |
| Architect/Engineer of Record: | Johnson Controls |
| Construction Manager: | Mitchell Shelton |
| Aim Project Number: | 0110-2017 |

Reviewer Information

| | | | |
|----------------|-------------|-----------------|------------|
| Reviewer Name: | Cary Redman | Date Received: | 12/13/2017 |
| Disposition: | Approved | Date Completed: | 2/5/2018 |

Status Statement

Note: A new DGMS device as part of the EBB Takayama Lab Renovation.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Fire Alarm 2017-FA-293
-