
Plan Review Summary

Building Information

Project Name:	DiLeo Lab	Floor/Room #:	205
Building #:	84	Department:	Aerospace Engineering
Occupancy Type:	Business	Budget:	\$250,000.00
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	
Architect/Engineer of Record:	William Oswell
Construction Manager:	
Aim Project Number:	0031-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	12/20/2017
Disposition:	Approved	Date Completed:	1/3/2018

Status Statement

Note: A new fire alarm device to be added as part of the DiLeo Lab renovation.

Review Comments:

1. All devices must match existing devices and FACP brand.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Fire Alarm 2017-FA-300
-