

---

## Plan Review Summary

---

### Building Information

Project Name:	Tech Tower Registrar Suite Phase I [FS]	Floor/Room #:	Ground Level
Building #:	035	Department:	Registrar Suite
Occupancy Type:	Business	Budget:	\$250,000
Construction Type:	VB	Type of Review:	Fire Suppression Review

---

### Project Management

Project Manager:	Liz Punch
Architect/Engineer of Record:	Eric Clementi, SWI
Construction Manager:	Liz Punch
Aim Project Number:	0085-2017

---

### Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	1/23/2017
Disposition:	Approved	Date Completed:	2/15/2017

---

### Status Statement

Note: A sprinkler system modification as part of the Tech Tower Registrar's suite renovation.

### Review Comments:

1. Approved as submitted.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Pre-Construction Meeting
2. Sprinkler Pipe Inspections
3. Rough-in
4. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
5. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
6. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issue

1. Fire Suppression System 2017-FS-019
-