
Plan Review Summary

Building Information

Project Name:	West Campus Dining Commons	Floor/Room #:	N/A
Building #:	209 (NEW)	Department:	Dining, Campus Services, College of Music
Occupancy Type:	Business	Budget:	\$29,000,000
Construction Type:	IIB	Type of Review:	Fire Suppression Review

Project Management

Project Manager:	Kim Wilson
Architect/Engineer of Record:	Cooper Carry Lake Flato / Christopher Biven
Construction Manager:	Kim Wilson
Aim Project Number:	0268-2015

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	2/24/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	3/16/2017

Status Statement

Note: A sprinkler system installation for West Campus Dining Hall.

Review Comments:

1. Approved as submitted.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Sprinkler Pipe Inspections
2. Rough-in
3. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
4. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
5. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System 2017-FS-045