
Plan Review Summary

Building Information

Project Name:	Paper Tricentennial Additional Ventilation & Boiler Room	Floor/Room #:	Boiler Room
Building #:	129	Department:	N/A
Occupancy Type:	Business	Budget:	N/A
Construction Type:	Choose an item.	Type of Review:	Fire Suppression Review

Project Management

Project Manager:	Sam Dahdah
Architect/Engineer of Record:	Sam Dahdah
Construction Manager:	Corey Pressley
Aim Project Number:	0223-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	3/10/2017
Disposition:	Approved	Date Completed:	3/22/2017

Status Statement

Note: Relocating sprinkler head at the Paper Tricentennial Additional Ventilation & Boiler Room

Review Comments:

1. Approved.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System 2017-FS-55