
Plan Review Summary

Building Information

Project Name:	North Ave Chiller #2 Replacement	Floor/Room #:	Main Mechanical Room
Building #:	191	Department:	GT Housing
Occupancy Type:	Business	Budget:	N/A
Construction Type:	IIB	Type of Review:	Fire Suppression Review

Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	Johnson, Spellman & Associates, Inc.
Construction Manager:	N/A
Aim Project Number:	0147-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	3/30/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	4/25/2017

Status Statement

Note: North Avenue Chiller room sprinkler line work.

Review Comments:

1. Add sectional valve to sprinkler supply line per Larry Labbe's conversation.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Pre-Construction Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System 2017-FS-72
-