

Plan Review Summary

Building Information

Project Name:	Price Gilbert Crosland Tower Renewal	Floor/Room #:	Basement thru 7th floor
Building #:	100	Department:	Library
Occupancy Type:	Business	Budget:	\$68,000,000
Construction Type:	Choose an item.	Type of Review:	Crane/Construction

Project Management

Project Manager:	Gary Petherick
Architect/Engineer of Record:	Jeremy Kahm/BNIM
Construction Manager:	Gary Petherick
Aim Project Number:	CO146-2014

Reviewer Information

Reviewer Name:	Larry Labbe	Date Received:	11/30/2017
Disposition:	Approved	Date Completed:	11/30/2017

Status Statement

Note:

Review Comments:

1.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. Underground Pressure Test
4. System Flush
5. Sprinkler Pipe Inspections
6. Rough-in
7. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
8. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)

9. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

Permits Issued:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

