

## Plan Review Summary

### Building Information

Project Name:	Woodruff Dining Hall	Floor/Room #:	1
Building #:	116	Department:	College Of Engineering
Occupancy Type:	Business	Budget:	\$150,000.00
Construction Type:	IIB	Type of Review:	Construction

### Project Management

Project Manager:	Brad Morris
Architect/Engineer of Record:	Becky Williams, HLG Studio
Construction Manager:	Brad Morris
Aim Project Number:	0089-2018

### Reviewer Information

Reviewer Name:	Larry Labbe	Date Received:	1/3/2018
Disposition:	Approved	Date Completed:	1/26/2018

### Status Statement

Note: Minor renovation of an existing assembly area. Space was previously used as dining hall and will now be used as research area utilizing an assembly occupancy

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System
2. Fire Alarm

### Permits Issued:

1. Construction / Interior Renovation: 2018-CP-004

