
Plan Review Summary

Building Information

Project Name:	Bunger Henry Renovation Rm 235	Floor/Room #:	235
Building #:	86	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$25,000.00
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	William T Oswell
Architect/Engineer of Record:	William T Oswell
Construction Manager:	William T Oswell
Aim Project Number:	0106-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	1/23/2018
Disposition:	Approved	Date Completed:	2/9/2018

Status Statement

Note: The Bungler Henry Renovation Rm 235 to add a dump sink and new LED lighting.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2018-CP-024
-