

Plan Review Summary

Building Information

Project Name:	Football Locker Rm Reno-Bobby Dodd Stdm	Floor/Room #:	1st Floor, North End Zone
Building #:	017	Department:	GT Athletics Association
Occupancy Type:	Business	Budget:	\$3.5 M
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Heery/Marc Clear
Construction Manager:	JE Dunn/Bryan Steed
Aim Project Number:	2018-0050

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	1/29/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	2/13/2018

Status Statement

Note: The Football Locker Room Renovation at-Bobby Dodd Stadium.

Review Comments:

1. Sheet FK101- All fire protection plans (Sprinkler and Fire Alarm Shop Drawings) must be submitted separately.
2. Provide hazardous chemical MSDS/SDS from chemical manufacture.
3. Fire alarm devices installed in the spa rooms must be moisture and chemical resistant.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. Rough-in
4. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
5. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
6. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation 2018-CP-031
-

