

151 Sixth Street, Suite 341 Atlanta, Georgia 30332 404-894-FIRE (3473)

Plan Review Summary

Building Information

Project Name: Burge Deck LED Lighting Upgrade

dige beck LLb Lighting Opgrade

Building #: 009

Occupancy Type: Other

Construction Type: IIB

Floor/Room #: All

Department:

Budget: \$195,910.00 Type of Review: Construction

Project Management

Project Manager: Malte Weiland
Architect/Engineer of Record: Newcomb & Boyd
Construction Manager: Lusk & Company

Aim Project Number: 2018-0046

Reviewer Information

Reviewer Name: Cary Redman Date Received: 2/5/2018

Disposition: Approved w/ Additional Requirements Date Completed: 3/16/2018

Status Statement

Note: The Burge Deck LED Lighting Upgrade

Review Comments:

1. The light testing must be performed during low light conditions.

General Note:

- 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request
- 2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

- 1. Fire Safety Office Project Kick-Off Meeting
- 2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

Construction / Interior Renovation