

## Plan Review Summary

### Building Information

Project Name:	Facilities Garage/Warehouse Rated Storage Closet	Floor/Room #:	201
Building #:	067	Department:	Facilities Management
Occupancy Type:	Storage	Budget:	\$9,600
Construction Type:	IIB	Type of Review:	Construction

### Project Management

Project Manager:	Fenella Bryant
Architect/Engineer of Record:	Ngugi Mathu
Construction Manager:	Fenella Bryant
Aim Project Number:	0189-2018

### Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	2/8/2018
Disposition:	Approved	Date Completed:	3/19/2018

### Status Statement

Note: the Facilities Garage/Warehouse Rated Storage Closet waste oil storage room.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System
2. Fire Alarm

### Permits Issued:

1. Construction / Interior Renovation 2018-CP-037