

Plan Review Summary

Building Information

Project Name:	GTRI 1604 3rd Floor Secure Space	Floor/Room #:	Third Floor rooms 314 to 320C
Building #:	790	Department:	GTRI
Occupancy Type:	Business	Budget:	\$69,500
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	Spencer Bristol-Doug Bristol
Construction Manager:	Elizabeth Punch
Aim Project Number:	0202-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	2/12/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	3/20/2018

Status Statement

Note: The GTRI 1604 3rd Floor Secure Space renovation.

Review Comments:

1. Sheet T-3 Install smoke detectors in the workroom and conference room in accordance with yellow book requirements.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

1. Demolition
2. Construction / Interior Renovation 2018-CP-048