
Plan Review Summary

Building Information

Project Name:	The Kendeda Building-Construction Trailer	Floor/Room #:	N/A
Building #:	210	Department:	N/A
Occupancy Type:	Other	Budget:	N/A
Construction Type:	VB	Type of Review:	Construction

Project Management

Project Manager:	John DuConge'
Architect/Engineer of Record:	N/A
Construction Manager:	Matt Williams (Skanska USA)
Aim Project Number:	0418-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	3/8/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	4/10/2018

Status Statement

Note: The The Kendeda Building-Construction Trailer construction plan review.

Review Comments:

1. Sheet A1.1- Install a smoke detector in the open office area.
2. Sheet C1- Install 2A10BC Fire extinguisher in accordance with note 14 in General Comments.
3. Sheet A1- Must provide a flush egress discharge at all exits.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2018-CP-079
-