

Plan Review Summary

Building Information

Project Name:	Wardlaw Center-F53 Renovation	Floor/Room #:	Field Level 053F
Building #:	047	Department:	Institute Communications
Occupancy Type:	Business	Budget:	\$52,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Amber Chellis-Omedo
Architect/Engineer of Record:	Amber Chellis-Omedo, Brian Clarke, Sam Daddah
Construction Manager:	TBD
Aim Project Number:	0107-2018

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	3/14/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	3/29/2018

Status Statement

Note: The Wardlaw Center-F53 Renovation of two offices.

Review Comments:

1. Sheet E 102- Install a ceiling mount horn strobe .

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation 2018-CP-086
-

