

## Plan Review Summary

### Building Information

Project Name:	Van Leer Interdisciplinary Design Commone	Floor/Room #:	
Building #:	85	Department:	ECE
Occupancy Type:	Business	Budget:	\$11,000,000
Construction Type:	IIB	Type of Review:	Construction

### Project Management

Project Manager:	Gary Petherick
Architect/Engineer of Record:	BLDGS
Construction Manager:	Steve Summers
Aim Project Number:	C0270-2015

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	3/16/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	4/10/2018

### Status Statement

Note: Van Leer Elevator

### Review Comments:

1. All penetrations must be sealed

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Rough-in
3. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
4. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
5. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Construction / Interior Renovation: 2018-CP-089