

Plan Review Summary

Building Information

Project Name:	Hinman Courtyard Student Installation	Floor/Room #:	Outside
Building #:	051	Department:	School of Architecture
Occupancy Type:	Business	Budget:	\$200,000
Construction Type:	Choose an item.	Type of Review:	Construction

Project Management

Project Manager:	Kim Wilson
Architect/Engineer of Record:	Uzun & Case
Construction Manager:	Kim Wilson
Aim Project Number:	0287-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/22/2018
Disposition:	Approved	Date Completed:	4/11/2018

Status Statement

Note: Install a pavilion and wall at Hinman Courtyard

Review Comments:

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Rough-in
3. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
4. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
5. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation

Permits Issued:

1. Demolition
 2. Construction / Interior Renovation 2018-CP-091
-

