
Plan Review Summary

Building Information

Project Name:	Curran Deck LED Lighting	Floor/Room #:	All
Building #:	139	Department:	Parking & Transportation Services
Occupancy Type:	Business	Budget:	\$528,728
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Malte Weiland
Architect/Engineer of Record:	Erin Keeney
Construction Manager:	
Aim Project Number:	2018-0046

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	3/29/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	4/11/2018

Status Statement

Note: The Curran Deck LED Lighting plans.

Review Comments:

1. All testing must be during in low light conditions and witnessed by Ga Tech fire safety office personnel.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2018-CP-099
-