

Plan Review Summary

Building Information

Project Name:	Edge Building Dining Hall Renovation	Floor/Room #:	2nd Floor
Building #:	018	Department:	Athletics
Occupancy Type:	Assembly	Budget:	1M
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Fenella Bryant
Architect/Engineer of Record:	Make3 Jim Winer
Construction Manager:	Fenella Bryant
Aim Project Number:	0299-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	4/17/2018
Disposition:	Approved	Date Completed:	4/24/2018

Status Statement

Note: Dinning Hall Renovation

Review Comments:

1. None

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation

Permits Issued:

1. Demolition
2. Construction / Interior Renovation: 2018 – CP -123