
Plan Review Summary

Building Information

Project Name:	A. French-Office 001 Renovation	Floor/Room #:	Basement -001
Building #:	030	Department:	Administration and Finance
Occupancy Type:	Business	Budget:	\$105,000
Construction Type:	IVA	Type of Review:	Construction

Project Management

Project Manager:	Allison Gerstung
Architect/Engineer of Record:	Maria de Mar Ceballos
Construction Manager:	Fenella Bryant
Aim Project Number:	0144-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	4/23/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	5/1/2018

Status Statement

Note: French Office Renovation

Review Comments:

1. Occupant Load sign must be posted
2. Emergency Light required

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation

Permits Issued:

1. Demolition
 2. Construction / Interior Renovation
-