

## Plan Review Summary

### Building Information

Project Name:	ITG Campus Door Access Update-Skiles	Floor/Room #:	Ground, 1st and 2nd Floor
Building #:	002	Department:	School of Chemistry/Biochemistry
Occupancy Type:	Business	Budget:	\$301,278
Construction Type:	IIB	Type of Review:	Construction

### Project Management

Project Manager:	Carla Barbour
Architect/Engineer of Record:	GA Tech ITG-Donald Smith
Construction Manager:	
Aim Project Number:	0246-2018

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/1/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	5/4/2018

### Status Statement

Note: Access-controlled doors update ITG Campus School of Chemistry/Biochemistry 1<sup>st</sup> and 2<sup>nd</sup> floors

### Review Comments:

1. If any doors are going to be access-controlled egress door assemblies they shall be in accordance with the 2012 edition of NFPA 101 7.2.1.6.2; a sensor shall be provided on the egress side to unlock in the direction of egress upon detection, door leaves shall automatically unlock upon loss of power, door locks shall unlock by manual release, activation of the building fire-protective signaling system shall unlock the door leaves, activation of manual fire alarm shall unlock door leaves, activation of building fire sprinkler system shall unlock door leaves, the egress side of the doors shall be provided with emergency lighting.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Construction / Interior Renovation

**Permits Issued:**

1. Construction / Interior Renovation; 2018-CP-153

