

Plan Review Summary

Building Information

Project Name:	Petit Microelectronics Building Lab 246	Floor/Room #:	246
Building #:	095	Department:	Nano Tech
Occupancy Type:	Business	Budget:	\$78,269
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Eric Clementi
Architect/Engineer of Record:	Eric Clementi
Construction Manager:	Corey Pressley
Aim Project Number:	0143-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/2/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	5/2/2018

Status Statement

Note: Renovation of Petit Microelectronics Building Lab 246

Review Comments:

1. Is or will there be any compressed or liquified gas cylinders present, if so please show compliance with the 2011 edition of NFPA 45, chapter 11.
2. Please show compliance with the 2011 edition of NFPA 45, chapter 13 Hazard Identification.
3. MSDS sheets are required to be on site for inspection and review of inventory.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Rough-in
3. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
4. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
5. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation; 2018-CP-159

