

## Plan Review Summary

### Building Information

Project Name:	GTRI 1699 Fifth Floor Closed Room	Floor/Room #:	
Building #:	790	Department:	GTRI
Occupancy Type:	Business	Budget:	\$450,000
Construction Type:	IIB	Type of Review:	Construction

### Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	Doug Bristol
Construction Manager:	Jennifer Disotell
Aim Project Number:	0320-218

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/10/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	5/10/2018

### Status Statement

Note: GTRI 1699 Fifth Floor Closed Room

### Review Comments:

1. Door needs labeled "FACP Inside" where panel will be located
2. Occupant load signs to be posted

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
4. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
5. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

**Permits Issued:**

1. Demolition
  2. Construction / Interior Renovation      2018-CP-173
  3. Fire Suppression System
  4. Fire Alarm
- 

