

---

## Plan Review Summary

---

### Building Information

Project Name:	Printing & Copying Services-Geothermal HVAC System Replacement-REVISION	Floor/Room #:	Building Wide-Mech/Elec
Building #:	138	Department:	Facilities-O&M
Occupancy Type:	Business	Budget:	\$475,000
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	Craig Forte
Architect/Engineer of Record:	Seth Spangler
Construction Manager:	Jamie Ready
Aim Project Number:	0035-2016

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/11/2018
Disposition:	Approved	Date Completed:	5/14/2018

---

### Status Statement

Note: Geothermal HVAC System Replacement; Printing & Copying Services

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Rough-in
3. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
4. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
5. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

### Permits Issued:

1. Construction / Interior Renovation: 2018-CP-179
-