

151 Sixth Street, Suite 341 Atlanta, Georgia 30332 404-894-FIRE (3473)

Plan Review Summary

Building Information

Project Name: MRDC 2200 Pod Invention Studio-Revision

Revision Floor/Room #:

2nd Floor 2200 Pod

Building #: 135

Mechanical Engineering

Occupancy Type: Business

Budget:

Department:

\$750,000

Buuget.

\$750,000

Type of Review:

Construction

Project Management

Project Manager:

Construction Type:

Bill Oswell

Architect/Engineer of Record:

HLG

Construction Manager:

Christina Fannin

Aim Project Number: 0067-2018

IJΒ

Reviewer Information

Reviewer Name:

Jerry Marrison

Date Received:

5/14/2018

Disposition:

Approved w/ Additional Requirements

Date Completed:

5/14/2018

Status Statement

Note: MRDC 2200 Pod Invention Studio-Revision

Review Comments:

- 1. Locking 2 1/2 FDC caps will be required
- 2. Knox Box if not installed must be with current keys
- 3. Max Occupant Load Sign will be posted
- 4. Location of spare heads and wrench will be disclosed per NFPA 13
- 5. Riser Room door will be labeled per code
- 6. FDC sign or standpipe sign will be posted as described by code.

General Note:

- 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request
- Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

- 1. Fire Suppression
- 2. Fire Alarm

Inspections Required:

- Fire Safety Office Project Kick-Off Meeting
- 2. Sprinkler Pipe Inspections
- 3. Rough-in
- 4. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
- 5. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 6. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

- Demolition
- Construction / Interior Renovation Fire Suppression System
- 4. Fire Alarm

Permits Issued:

1. Demolition

2. Construction / Interior Renovation 2018-CP-181

