

## Plan Review Summary

### Building Information

Project Name:	GTRI Cobb Lockheed L-22 Renovation-Revision	Floor/Room #:	All
Building #:	762	Department:	GT Design & Construction
Occupancy Type:	Business	Budget:	\$12M
Construction Type:	IIA	Type of Review:	Construction

### Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Mike Moreland
Construction Manager:	Dan Hesse
Aim Project Number:	0320-2016

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/15/2018
Disposition:	Approved	Date Completed:	5/15/2018

### Status Statement

Note: Cobb County Lockheed L-22; GTRI Renovation

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

### Permits Issued:

