

Plan Review Summary

Building Information

Project Name:	GTRI Cobb Lockheed L-12 Renovation-Revision	Floor/Room #:	1st Floor
Building #:	763	Department:	GT Design and Construction
Occupancy Type:	Business	Budget:	\$12M
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Mike Moreland
Construction Manager:	Dan Hesse
Aim Project Number:	0320-2016

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/16/2018
Disposition:	Approved	Date Completed:	5/17/2018

Status Statement

Note: Renovation GTRI Cobb Lockheed L-12

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. Rough-in
4. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
5. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
6. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2018-CP-185
-

