

Plan Review Summary

Building Information

Project Name:	Densification Project for International Education-Savant	Floor/Room #:	2nd Floor
Building #:	038	Department:	International Education
Occupancy Type:	Business	Budget:	\$140,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Allison Gerstung
Architect/Engineer of Record:	Lisa Vanderloo
Construction Manager:	Mitchell Shelton
Aim Project Number:	0389-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/24/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	5/24/2018

Status Statement

Note: Demo Closet in office and add new electrical devices; renovation

Review Comments:

1. A Dead-end exists in the corridor inside a room that is labeled office, room 207; this area is a corridor and approximately a 33 feet dead-end exist at this location.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Alarm

Permits Issued: Construction / Interior Renovation: 2018-CP-198