
Plan Review Summary

Building Information

Project Name:	Quad Cafe Renovation-MS&E Dumpster Location	Floor/Room #:	Old Quad Café Areas
Building #:	167	Department:	Auxiliary Services
Occupancy Type:	Business	Budget:	\$234,860.00
Construction Type:	IIB	Type of Review:	Construction-Dumpster Location

Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Barbara Amason
Construction Manager:	N/A
Aim Project Number:	0089-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/26/2018
Disposition:	Approved	Date Completed:	6/28/2018

Status Statement

Note: Dumpster Location

Review Comments:

1. No issues

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation

Permits Issued:

1. Construction / Interior Renovation 2018-CP-236
-