Plan Review Summary

151 Sixth Street, Suite 341 Atlanta, Georgia 30332 404-894-FIRE (3473)

Building Information			
Project Name:	ACC Network Operations Center Site Logistics	Floor/Room #:	
Building #:	032	Department:	GT Athletics Association
Occupancy Type:	Business	Budget:	\$10,000,000.00
Construction Type:	IIB	Type of Review:	Construction
Project Management			
Project Manager:	Carla Barbour		
Architect/Engineer of Record: Jim Winer-Make3			
Construction Manage	r: Carla Barbour		
Aim Project Number:	C0404-2018		
Reviewer Information			
Reviewer Name:	Jerry Marrison	Date Received:	6/26/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/29/2018
Status Statement			
Note: Logistics Pla	┉╵║║┃ <mark>┟┢╌</mark> ┥╺ ┎ ┢┱┱┱		
Review Comments:			
1. No parking in front of 20' gate to allow for fire apparatus to enter			
General Note:			
	uests: http://www.ehs.gatech.edu/fire/inspection-r nit Request: http://www.ehs.gatech.edu/fire/permi		

- Plan / Shop Drawings Required:
 - 1. Fire Suppression
 - 2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting

Georgia Environmental Tech Health & Safety

Fire Safety

- 2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

- 1. Demolition
- 2. Construction / Interior Renovation

Permits Issued:

- 1. Demolition
- 2. Construction / Interior Renovation

2018-CP-237