

Plan Review Summary

Building Information

Project Name:	Edge Lobby Refresh	Floor/Room #:	1st Floor Lobby
Building #:	018	Department:	Athletics
Occupancy Type:	Business	Budget:	
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Derek Grice
Architect/Engineer of Record:	Jim Winer
Construction Manager:	Bobby West
Aim Project Number:	

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/23/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	7/24/2018

Status Statement

Note: Add wall; relocate fire alarm annunciator

Review Comments:

1. A separate fire alarm permit shall be required. Please submit fire alarm shop drawings indicating the change/modifications to the fire alarm system.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2018-CP-263