
Plan Review Summary

Building Information

Project Name:	Swann Stair Refinishing	Floor/Room #:	Stairs 109/119 (all floors)
Building #:	039	Department:	Area IV
Occupancy Type:	Business	Budget:	
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	David Tate
Architect/Engineer of Record:	Maria del Mar Ceballos
Construction Manager:	David Tate
Aim Project Number:	

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	8/8/2018
Disposition:	Approved	Date Completed:	8/9/2018

Status Statement

Note: Refinishing exit stairs 109 and 119

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work
- 3.

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2018-CP-273
-