

Plan Review Summary

Building Information

Project Name:	Skiles-014 & 014A Ground Floor	Floor/Room #:	Ground Floor 014 & 014A
Building #:	002	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$150,000
Construction Type:	IIA	Type of Review:	Construction

Project Management

Project Manager:	Maria del Mar Ceballos
Architect/Engineer of Record:	Maria del Mar Ceballos
Construction Manager:	Corey Pressley
Aim Project Number:	0450-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	8/13/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	8/14/2018

Status Statement

Note: Renovation of two rooms; business occupancies

Review Comments:

1. The existing fire alarm system shall come into compliance in these two rooms regarding NFPA 72 and a partial smoke detection system in accordance with Georgia Tech yellow book Standards.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation

2018-CP-279