

Plan Review Summary

Building Information

Project Name:	Kaiser Lab-Ford ES&T	Floor/Room #:	ES&T 3107
Building #:	147	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$418,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	Warren Epstein Associates
Construction Manager:	Mitchell Shelton
Aim Project Number:	0479-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	8/24/2018
Disposition:	Approved	Date Completed:	8/27/2018

Status Statement

Note: Refit of lab for new occupant

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

Permits Issued:

1. Demolition
2. Construction / Interior Renovation

2018-CP-292