

---

## Plan Review Summary

---

### Building Information

Project Name:	Dalney Building-Crane Plan (Steel)	Floor/Room #:	All
Building #:	204	Department:	GTRC/Parking and Transportation
Occupancy Type:	Business	Budget:	\$39M
Construction Type:	IB	Type of Review:	Construction-Crane Plan

---

### Project Management

Project Manager:	Brad Morris
Architect/Engineer of Record:	Scott Southerland, Collins Cooper Carusi
Construction Manager:	Fredrik Nilsson, New South Construction
Aim Project Number:	0370-2017

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	8/27/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	8/27/2018

---

### Status Statement

Note: Crane Plan

### Review Comments:

1. Please make sure there is a flagger while crane is lifting
2. Make sure students and guest cannot access the area where crane will be operating
3. Provide operators certification to operate crane and drivers license.

### In

### Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System

### Permits Issued:

1. Demolition
2. Construction / Interior Renovation

2018-CP-294

---