

## Plan Review Summary

### Building Information

Project Name:	Groseclose Steam Repair	Floor/Room #:	Outside of Building
Building #:	56	Department:	Facilities
Occupancy Type:	Business	Budget:	\$400,000
Construction Type:	IIB	Type of Review:	Construction

### Project Management

Project Manager:	Fenella Bryant
Architect/Engineer of Record:	Don Alexander
Construction Manager:	
Aim Project Number:	0037-2019

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	8/30/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	8/30/2018

### Status Statement

Note: Temporary Door; underground steam & condensate line replacement

### Review Comments:

1. The temporary door shall have the same type hardware as the permanent door being temporarily barricaded while the work is being done.
2. The temporary sidewalk proposed shall be flush with existing paths.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Construction / Interior Renovation: 2018-CP-297