
Plan Review Summary

Building Information

Project Name:	College of Business-Door Accessibility	Floor/Room #:	1,2,3 multiple doors
Building #:	172	Department:	Scheller College of Business
Occupancy Type:	Business	Budget:	\$150,000
Construction Type:	IB	Type of Review:	Construction

Project Management

Project Manager:	Amber Chellis-Omedo
Architect/Engineer of Record:	Amber Chellis-Omedo
Construction Manager:	Mitchell Shelton
Aim Project Number:	0394-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	8/31/2018
Disposition:	Approved	Date Completed:	9/4/2018

Status Statement

Note: Door Accessibility

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2018-CP-303
-