# **Plan Review Summary**

| Building Information                                 |   |                 |                              |
|--|---|-----------------|------------------------------|
| Project Name:  | School of Modern Languages Renovation               | Floor/Room #:   | 1 & 3                        |
| Building #:  | 039   | Department:     | Ivan College of Liberal Arts |
| Occupancy Type:                                      | Business  | Budget:         | Estimate Phase               |
| Construction Type:                                   | IVB   | Type of Review: | Construction-Consultation    |
| Project Management                                   |   |                 |                              |
| Project Manager:                                     | Maria del Mar Ceballos                              |                 |                              |
| Architect/Engineer of Record: Maria del Mar Ceballos |   |                 |                              |
| Construction Manage                                  | er: Mitchell Shelton                                |                 |                              |
| Aim Project Number:                                  | 0439-2018   |                 |                              |
| Reviewer Information                                 |   |                 |                              |
| Reviewer Name:                                       | Jake LeJeune  | Date Received:  | 8/31/2018                    |
| Disposition:   | Consultation Provided - Submital Required Elsewhere | Date Completed: | 9/4/2018                     |

#### Status Statement

Note: Renovation of Office; Business areas

#### General Note:

- 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request
- 2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot\_work

## Plan / Shop Drawings Required:

- 1. Fire Suppression
- 2. Fire Alarm

## Inspections Required:

- 1. Fire Safety Office Project Kick-Off Meeting
- 2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
- 3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

#### Permits Required:

- 1. Construction / Interior Renovation
- 2. Fire Suppression System
- 3. Fire Alarm

## Permits Issued:

1. Construction / Interior Renovation:

2018-CP-304

