

Plan Review Summary

Building Information

Project Name:	Daniel Lab Roof Replacement	Floor/Room #:	N/A
Building #:	022	Department:	Facilities O&M
Occupancy Type:	Business	Budget:	\$410,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	JW Robinson/Larry Cornelius
Construction Manager:	Jennifer Disotell
Aim Project Number:	0290-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	9/11/2018
Disposition:	Approved	Date Completed:	9/13/2018

Status Statement

Note: Roof Replacement

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

- | | |
|---------------------------------------|-------------|
| 1. Construction / Interior Renovation | 2018-CP-308 |
|---------------------------------------|-------------|