

---

## Plan Review Summary

---

### Building Information

Project Name:	MRR(Weber 1 & 2) Re-roof Project	Floor/Room #:	Roof
Building #:	84 and 98	Department:	Facilities
Occupancy Type:	Business	Budget:	\$500,000
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	Jennifer Disotell
Architect/Engineer of Record:	William T Oswell
Construction Manager:	Jennifer Disotell
Aim Project Number:	0290-2018

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	9/18/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	9/19/2018

---

### Status Statement

Note: Reroofing of buildings

### Review Comments:

1. Follow hot works requirements
2. Fusible link test required for fire/smoke skylight

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Demolition
2. Construction / Interior Renovation

### Permits Issued:

1. Demolition
  2. Construction / Interior Renovation
- 2018-CP-313
-