

Plan Review Summary

Building Information

Project Name:	ITG Door Access Upgrade-ISYE & Groseclose-O'Keefe	Floor/Room #:	
Building #:	33	Department:	ITG
Occupancy Type:	Business	Budget:	\$920,538
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Carla Barbour
Architect/Engineer of Record:	GA TECH ITG-Donald Smith
Construction Manager:	
Aim Project Number:	0029-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	10/22/2018
Disposition:	Approved	Date Completed:	10/26/2018

Status Statement

Note: Door Access Control

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

- | | |
|---------------------------------------|-------------|
| 1. Construction / Interior Renovation | 2018-CP-342 |
|---------------------------------------|-------------|