

Plan Review Summary

Building Information

Project Name:	EHS Auxiliary Heat	Floor/Room #:	Roof
Building #:	187	Department:	EHS
Occupancy Type:	Business	Budget:	\$40,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Tony Gonzalez, GA Tech
Architect/Engineer of Record:	Click here to enter text.
Construction Manager:	Tony Gonzalez
Aim Project Number:	0242-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	10/26/2018
Disposition:	Approved	Date Completed:	10/26/2018

Status Statement

Note: Auxiliary Heat Unit

Review Comments:

1. Approved

General Note:

1. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation

Permits Issued:

1. Demolition
2. Construction / Interior Renovation 2018-CP-348