

Plan Review Summary

Building Information

Project Name:	MRDC Weber 2nd Floor-Lobby Renovation	Floor/Room #:	2nd Floor
Building #:	135	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$150,000.00
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	HLG Studio
Construction Manager:	Cristina Fannin
Aim Project Number:	0179-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	11/1/2018
Disposition:	Approved	Date Completed:	11/5/2018

Status Statement

Note: Renovation to 2nd floor lobby only

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
 2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
 3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
 4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)
-
1. Fire Suppression System
 2. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation 2018-CP-355