
Plan Review Summary

Building Information

Project Name:	KAT Parking Lot at Techwood-Road Closure	Floor/Room #:	N/A
Building #:	N/A	Department:	GT Parking & Transportation
Occupancy Type:	Other	Budget:	\$650,000.00
Construction Type:	IIIB	Type of Review:	Construction-Road Closure

Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Andy Anderson, Treanor HL Architects
Construction Manager:	
Aim Project Number:	0095-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	11/14/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	11/15/2018

Status Statement

Note: New water line

Review Comments:

1. Metal plates must be on site
2. Backhoe and operator must be dedicated on site to be able to put plates in place in the event of an emergency
3. Plates must be in place when site unoccupied

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation

Permits Issued:

1. Construction / Interior Renovation 2018-CP-378
-