Plan Review Summary

Building Information						
Project Name:	Price G	ilbert-Full Building	FI	oor/Room #:	All	
Building #:	077		D	epartment:	GT Design and Construction	
Occupancy Ty	vpe: Busine	SS	В	udget:	\$30M	
Construction T	Type: IB	E U H	Ту	/pe of Review:	Construction	
Project Management						
Project Manager: Lindsey Cottingham						
Architect/Engineer of Record: Jeremy Kahm						
Construction N	Manager:	Ryan Miller				
Aim Project N	umber:	2014-0146				
Reviewer Information						
Reviewer Nam	ne: Jake Le	eJeune	Da	ate Received:	11/27/2018	
Disposition:	Approv	ed	Da	ate Completed:	1/25/2019	
Note: Renovation General Note: 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request 2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work Additional Requirements (as needed):						
 Fire Emergency Response Plans Red Book Completion and Fixed Location Designation 						
Plan / Shop Drawings Required:						
 Fire Suppression Fire Alarm 						
Inspections Required:						
 Thrust Underg System Sprinkle Rough- 50% W 80% Ce 	 2. Thrust Block Inspections 3. Underground Pressure Test 4. System Flush 5. Sprinkler Pipe Inspections 6. Rough-in 7. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.) 					
9 100% Construction Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete						

Permits Required:

Fire Safety

Georgia Environmental Tech Health & Safety

- 1. Demolition
- 2. Construction / Interior Renovation
- 3. Fire Suppression System
- 4. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation

2018-CP-391

