
Plan Review Summary

Building Information

Project Name:	Crosland Tower-IFC Section 510 Compliance	Floor/Room #:	All
Building #:	100	Department:	GT Design and Construction
Occupancy Type:	Business	Budget:	\$50M
Construction Type:	IB	Type of Review:	Construction

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Jeremy Kahm
Construction Manager:	Ryan Miller
Aim Project Number:	2014-0146

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	11/27/2018
Disposition:	Approved	Date Completed:	12/4/2018

Status Statement

Note: IFC 510 Radio Compliance

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2018-CP-392
-