

151 Sixth Street, Suite 341 Atlanta, Georgia 30332 404-894-FIRE (3473)

Plan Review Summary

Building Information

CODA Tenant Fit Up (Floors 5-16) Project Name:

207

Building #:

Occupancy Type: **Business**

Construction Type: IΑ Floor/Room #: 5-16

> Department: **Design & Construction**

Budget: \$23M

Type of Review: Construction

Project Management

Project Manager: Architect/Engineer of Record:

Nancy Cartledge, C&W

Kara Thomas, ASD Devyn Blackstone, HITT

Construction Manager: Aim Project Number:

0009-2017

Reviewer Information

Reviewer Name: Jake LeJeune

Approved w/ Additional Requirements

Date Received:

11/28/2018

Date Completed: 11/28/2018

Status Statement

Disposition:

Note: Tenant build-out for floors 5-16; CODA

Review Comments:

Please show compliance with the 2012 edition of NFPA 101.11.8.7 and provide emergency plans in accordance with 4.8.2; also show compliance with the 2012 IFC 404 Fire Safety and Evacuation Plans; this shall be done before the 100% Final Inspection.

General Note:

- 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request
- Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

- Fire Emergency Response Plans
- Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

- 1. Fire Suppression
- Fire Alarm

Inspections Required:

- Fire Safety Office Project Kick-Off Meeting 1.
- 2. Thrust Block Inspections
- 3. Underground Pressure Test
- 4. System Flush
- 5. Sprinkler Pipe Inspections
- 6. Rough-in
- 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)

- 8. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 9. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

- 1. Demolition
- 2. Construction / Interior Renovation
- 3. Fire Suppression System
- 4. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation

2018-CP-396

