

---

## Plan Review Summary

---

### Building Information

Project Name:	Vision Glass(Doors)-Lyman Emerson Addition	Floor/Room #:	Floors 1,2, and 3
Building #:	029	Department:	CPSM
Occupancy Type:	Business	Budget:	5,000
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	Amber Chellis-Omedo
Architect/Engineer of Record:	Amber Chellis-Omedo
Construction Manager:	Cristina Fannin
Aim Project Number:	0051-2019

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	11/30/2018
Disposition:	Approved	Date Completed:	12/3/2018

---

### Status Statement

Note: Door swap

### Review Comments:

1. None

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Construction / Interior Renovation

### Permits Issued:

1. Construction / Interior Renovation 2018-CP-400
-