

Plan Review Summary

Building Information

Project Name:	O'Keefe Gymnasium-Video Board Install	Floor/Room #:	2ND Floor/Gymnasium
Building #:	033	Department:	Athletics
Occupancy Type:	Business	Budget:	
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Kaira Dempsey
Architect/Engineer of Record:	James E. Wright
Construction Manager:	Josh Caron
Aim Project Number:	180361

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	7/5/2018
Disposition:	Approved	Date Completed:	7/9/2018

Status Statement

Note: Video Board

Review Comments:

1. Non Comments

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation

Permits Issued:

1. Demolition
2. Construction / Interior Renovation 2018-CP-245