

Plan Review Summary

Building Information

Project Name:	IDEaS Renovation-FA	Floor/Room #:	124,125,129
Building #:	TSRB	Department:	
Occupancy Type:	Business	Budget:	\$3,650.00
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Maria Ceballos
Architect/Engineer of Record:	ASD/SKY-Kara Thomas
Construction Manager:	Jennifer Disotell
Aim Project Number:	0392-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	1/4/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	1/16/2018

Status Statement

Note: Fire alarm modifications in the TSRB renovations plans.

Review Comments:

1. Install smoke detectors in accordance with the Ga Tech Yellow Book Standard. See note and locations on drawing in red ink.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Fire Alarm 2018-FA-005